



<b>Number</b>	KIP-17363/G	<b>Replaces</b>	KIP-16911/G
<b>Issue date</b>	21-06-2023	<b>Contract number</b>	I 7000
<b>Due date</b>	20-06-2033	<b>Scope</b>	(EU) 2016/426 (9 March 2016)
<b>Report number</b>	140700134/14	<b>Module</b>	B (Type testing)
<b>PIN</b>	0476CQ0134		

## EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the Central heating condensing boilers, type(s):

**35 Tech ACS, 35 Tech, 35 Tech Export, AY 35,  
AY 50, 55.1 Tech, 55.1 Tech Export,  
75.1 Tech,  
AY 100, 100.2 Tech, 100.2 Tech Export**

Manufacturer

**ROBUR S.p.A.**

**Via Parigi 4/6**

**24040 Verdellino/Zingonia (BG) - Italy**

Meet the essential requirements as described in the  
**Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.**

Reference standard: EN 15502-1:2021, EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

# CERTIFICATE

**Kiwa Cermet Italia S.p.A.**  
Società con socio unico, soggetta all'attività di  
direzione e coordinamento di Kiwa Italia  
Holding Srl

Via Cadriano, 23  
40057 Granarolo dell'Emilia (BO)

**Unità locale**

Via Treviso 32/34  
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: [info@kiwacermet.it](mailto:info@kiwacermet.it)

[www.kiwa.it](http://www.kiwa.it)

[www.kiwacermet.it](http://www.kiwacermet.it)

**GASTEC**

**President**

*Giampiero Belcredi*



PRD N° 069B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC  
Signatory of EA, IAF and ILAC Mutual Recognition Agreements



**Number** KIP-17363/G **Page** 1 of 2  
**Issue date** 21-06-2023 **Scope** (EU) 2016/426 (9 March 2016)  
**Due date** 20-06-2033 **Module** B (Type testing)  
**Report number** 140700134/14  
**PIN** 0476CQ0134

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name: **ROBUR**

Types:

Model name	Heat Input (Hi)	
	CH Max – Min (kW)	DHW Max – Min (kW)
35 Tech ACS	34,0 – 4,1	34,0 – 4,1
35 Tech	34,0 – 4,1	--
35 Tech Export	34,0 – 4,1	--
AY 35	34,0 – 4,1	--
AY 50	50,0 – 5,0	--
55.1 Tech	50,0 – 5,0	--
55.1 Tech Export	50,0 – 5,0	--
75.1 Tech	75,0 – 3,7	--
AY 100	100,0 – 5,0	--
100.2 Tech	100,0 – 5,0	--
100.2 Tech Export	100,0 – 5,0	--

Appliance types:

Installation type:	AY 35, AY 50, AY 100	35 Tech ACS, 35 Tech, 35 Tech Export, 55.1 Tech, 55.1 Tech Export, 75.1 Tech, 100.2 Tech, 100.2 Tech Export
B23	X	X
B23p	X	X
B33	X	X
B53	X	X
C13	--	X
A3	--	X

**Number** KIP-17363/G **Page** 2 of 2  
**Issue date** 21-06-2023 **Scope** (EU) 2016/426 (9 March 2016)  
**Due date** 20-06-2033 **Module** B (Type testing)  
**Report number** 140700134/14  
**PIN** 0476CQ0134

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Gas groups:

Gas groups	mbar	75.1 Tech	35 Tech, 35 Tech Export, 35 Tech ACS, AY 35	55.1 Tech, 55.1 Tech Export, AY 50, 100.2 Tech, 100.2 Tech Export, AY 100
EY20	20	X	X	X
HY20	20;25	X	X	X
EK	20/25	X	X	X
LL	20	X	X	X
Esi	20/25	X	X	X
E(S)	20	X	X	X
E(R)	20	X	X	X
P	30; 37; 50	X	X	X
B/P	30; 37; 50	X	X	X
Lw	20	–	X	X
Ls	13	–	X	X
S	25	–	–	X
E	20	X	X	X
H	20;25	X	X	X

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Countries:

AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Remarks:

Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H<sub>2</sub>) when the appliance is set for the reference gas G20.

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.